

Designation Fire Cap Plus

File Number: EX16045

COMPANY

FIRE SUPPRESSION PRODUCTS

5210 Park Ave.

Hudsonville, MI 49426 United States

DESIGNATION INFO

Fire Cap Plus

Wetting Agent Concentrate

WETTING AGENTS	VALUE
Class A fire concentration, minimum	0.25 %
Class B fire concentration, minimum	0.3 %



The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."